

# **DESIGN DEVELOPMENT REPORT FINAL**

## **WITHLACOOCHEE WPCP IMPROVEMENTS**



### **VALDOSTA GEORGIA UTILITIES DEPARTMENT**

**PARSONS**



**AUGUST 2011**

# DESIGN DEVELOPMENT REPORT

## Table of Contents

<b>EXECUTIVE SUMMARY .....</b>	<b>ES-1</b>
ES.1 Project Summary .....	ES-1
ES.2 Recommended Facilities .....	ES-1
ES.3 Cost and Schedule .....	ES-1
<b>SECTION 1 INTRODUCTION .....</b>	<b>1-1</b>
1.1 Project Purpose and Objectives .....	1-1
1.2. Related Projects .....	1-2
<b>SECTION 2 BACKGROUND.....</b>	<b>2-1</b>
2.1 Service Area Description .....	2-1
2.2 Withlacoochee Service Area Sewer System .....	2-1
2.3 Withlacoochee WPCP.....	2-3
<b>SECTION 3 WASTEWATER FLOW CHARACTERISTICS AND IMPROVMENT OBJECTIVES .....</b>	<b>3-1</b>
3.1 Population and Flows.....	3-1
3.2 Design Flows .....	3-2
<b>SECTION 4 PROPOSED FACILITIES .....</b>	<b>4-1</b>
4.1 Withlacoochee WPCP Improvements.....	4-1
4.1.1 Summary of Expansion Concept .....	4-1
4.1.2 Basis of Design .....	4-1
4.1.2.1 Headworks .....	4-3
4.1.2.2 Equalization Storage .....	4-3
4.1.2.3 Gravity Outfall to the Existing WPCP.....	4-3
4.1.2.4 Ancillary Facilities .....	4-5
4.1.2.4.1 Odor Control .....	4-5
4.1.2.4.2 Electrical .....	4-5
4.2 Construction Sequencing .....	4-5
4.3 Projected Cost and Schedule.....	4-5

# DESIGN DEVELOPMENT REPORT

## LIST OF FIGURES

No.	Description
1-1	Site Plan
2-1	City of Valdosta Wastewater Service Areas
4-1	Withlacoochee Service Area Sewer System Improvements

## LIST OF TABLES

No.	Description
ES-1	Capital Cost Estimate
ES-2	Operation and Maintenance Cost Estimate
ES-3	Schedule
2-1	Withlacoochee WPCP Effluent Flow Limitations
3-1	Withlacoochee Basin Average Dry Weather Flow
3-2	Withlacoochee Basin Peak Hour Flow
4-1	Basis of Design
4-2	Projected Capital Cost
4-3	Projected Annual Operation and Maintenance Cost
4-4	Anticipated Construction Schedule

## LIST OF APPENDICES

**APPENDIX A – ENVIRONMENTAL INFORMATION DOCUMENT**

**APPENDIX B – FLOW PROJECTIONS**

**APPENDIX C – RELATED DOCUMENTS**



## **EXECUTIVE SUMMARY**

### **ES.1 PROJECT SUMMARY**

This Design Development Report (DDR) describes treatment plant improvements for the Withlacoochee Water Pollution Control Plant (WPCP) service area. Improvements will be issued as multiple construction packages to meet the needs of the City of Valdosta system while providing opportunities for local contractors to bid on the construction.

This project provides for a new headworks and flow equalization storage for the Withlacoochee WPCP. This project is being done in conjunction with sewer system improvements to eliminate the use of the 54-inch Withlacoochee Outfall which delivers flow to the existing Withlacoochee WPCP and replace it with two pump stations and a manifolded force main directly to the new headworks as described in a separate Preliminary Engineering Report (PER).

### **ES.2 RECOMMENDED FACILITIES**

The Withlacoochee WPCP will be upgraded by construction of a new headworks and flow equalization on property owned by the City of Valdosta near the existing Withlacoochee WPCP. The improvements involve the following elements:

- A new headworks facility including coarse screening and grit removal.
- A new 6 million gallon equalization storage tank.
- Gravity piping to the existing Withlacoochee WPCP.

### **ES.3 COST AND SCHEDULE**

The City of Valdosta anticipates funding the capital cost of this project either through FEMA or other funding resources. Operating costs and any debt service will be paid by revenue from the water and sewer service. The total capital cost of these improvements is estimated at \$5.2 million. The components of this capital cost are shown in Table ES-1. Operation and maintenance (O&M) costs for the improvements will increase the City of Valdosta's annual operating budget requirements. O&M costs for these facilities, including planned capital renewal and replacement costs, are projected to be \$79,000 per year. The components of this annual O&M cost are shown in Table ES-2.





**Table ES-1. Capital Cost Estimate**

Item	Cost, million dollars
<b>Withlacoochee WPCP Improvements</b>	
Design	0.2
Construction	5.0
<b>Total Projected Capital Cost</b>	<b>5.2</b>

**Table ES-2. Operations & Maintenance Cost Estimate**

Item	Average Operation and Maintenance Cost, dollars
<b>Withlacoochee WPCP Improvements</b>	
Labor	16,000
Electric Power	34,000
Maintenance	4,000
Renewal/Capital Replacements	15,000
Other	10,000
<b>Estimated Annual Average O&amp;M</b>	<b>79,000</b>

The milestones for implementation of these improvements are shown in Table ES-3. Under this schedule, the improvements will be completed in 2013.

**Table ES-3. Schedule**

Item	Anticipated Date
Detailed Design Complete	April 2012
Bid Opening	June 2012
Construction Contract Issued	July 2012
Construction Completion	October 2013
Testing, Startup and Training Completion	November 2013



## **SECTION 1 INTRODUCTION**

This Design Development Report (DDR) describes treatment plant improvements for the Withlacoochee Water Pollution Control Plant (WPCP). This project is being done in conjunction with improvements to the Withlacoochee service area sewer system presented in a separate Preliminary Engineering Report (PER). Section 1 presents an overview of the project purpose, objectives, and related projects. Improvements will be issued as multiple packages to meet the needs of the City of Valdosta system while providing opportunities for medium sized local contractors to bid on the construction.

### **1.1 PROJECT PURPOSE AND OBJECTIVES**

The outfall sewer to the Withlacoochee WPCP is located in the broad floodplain of the Withlacoochee River. Due to its location, the outfall is periodically underwater, allowing river water to directly inflow into manholes and other structures. The Withlacoochee service area wastewater flow to the interceptor combines with infiltration and inflow (I/I) into the collection system to overwhelm the collection and treatment systems. The outfall pipe is difficult to access making maintenance and operation of the collection system difficult. The City of Valdosta recognizes the need to address these sewer system issues, to protect receiving water quality, eliminate sanitary sewer overflows (SSOs) and provide for growth and economic development. This project is being done in conjunction with Withlacoochee service area sewer system improvements presented in a separate Preliminary Engineering Report (PER). Extreme rain events in April 2009 resulted in severe flooding of the Withlacoochee River and severely impacted the operation of the Withlacoochee WPCP. Approximately forty percent of the plant was flooded. Emergency construction of a 20-foot-high berm around the influent pump station controlled flooding, thus avoiding major influent lift station damage that would have resulted in an extended raw wastewater spill and extensive environmental impact.

The City of Valdosta has evaluated sewer flows and collection system condition. The system experiences higher than normal peaks during wet weather events. Flow monitoring and the sanitary sewer rehabilitation priorities are documented in 2010 engineering reports titled Sewer System Modeling and Capacity Evaluation Report, and Sanitary Sewer Condition Assessment and Rehabilitation Program Plan.

This project provides for the elimination of the influent lift station and headworks, replacing it with screening, degritting and equalization storage on property owned by the City of Valdosta at a higher elevation to protect it from flooding. An Environmental Information Document on the proposed property is included as Appendix A. Wastewater flows in the Withlacoochee collection system will be intercepted upstream of the 54-inch sewer and pumped to the new headworks and flow equalization facilities. The facilities are sized based on longer-term flows including peak



flow reductions, and are capable of handling current wet weather peak flow conditions. The 6 - million gallon equalization storage tank volume was based on analysis contained in the 2010 engineering reports referenced above. Wastewater flows will be equalized to provide for a more consistent flow rate with reduced peaks to the existing Withlacoochee WPCP and to maintain compliance with the plant's NPDES permit and protect receiving water quality.

This DDR describes the Withlacoochee WPCP improvements including the following:

- A new headworks facility including coarse screening and grit removal.
- A new 6 million gallon equalization storage tank.
- Gravity piping to the existing Withlacoochee WPCP.

This DDR provides a general description of the proposed scope of work and the criteria used in the selection of major equipment. This report forms the basis for the detailed design effort.

Topographic surveys were available for the new site of the headworks and equalization storage and included both aerial and limited ground run surveys. Figure 1-1 presents a site plan showing proposed facilities and how the site could accommodate a new Withlacoochee WPCP. Geotechnical engineering services including subsurface field investigations and laboratory analyses will provide information in support of the detailed foundation design.

## **1.2 RELATED PROJECTS**


The City of Valdosta has recently completed a system capacity and condition assessment of its sewer system. Based on this assessment, areas of the system were prioritized for the City's infiltration and inflow control efforts. Due to aging infrastructure, rehabilitation is expected to include lining existing older pipelines, replacing pipelines and structures, construction of relief sewers, and both trenched and trenchless pipe rehabilitation. The City of Valdosta has initiated a sewer system rehabilitation and replacement program. They have CCTV recorded 2 interceptors in the areas of the system identified as high priority. The City of Valdosta is rehabilitating 20 manholes and developing an ongoing listing of other manholes requiring rehabilitation. They anticipate work beginning on at least 20 additional manholes within the next year. Lift stations in the system are being replaced. Planning is also underway for elimination of three dated aerial sewer lines near the new Remer Pump Station. Contracts have been issued for the replacement of four lift stations, including 2 damaged in the 2009 flood event. The remaining ten lift stations will be replaced as funding is identified.

The City of Valdosta is developing a Sewer System Improvement Project which will eliminate the use of the 54-inch outfall sewer, and pump flows from the sewer system directly to the new headworks and equalization storage. These Sewer System Improvements are being planned in conjunction with these Withlacoochee WPCP Improvements and are presented in a separate Preliminary Engineering Report. The estimated capital cost and the annual average operations



and maintenance cost for the Withlacoochee WPCP improvements are 27.1 million dollars and 470,000 dollars, respectively.

J:\Withlacoochee WWTP\Construction Drawings\Phase 1\00\_General\G07 SITE PLAN.dwg





## **SECTION 2 BACKGROUND**

The City of Valdosta provides wastewater collection and treatment services throughout the City limits. The Withlacoochee WPCP discharges into the Withlacoochee River, and the Mud Creek WPCP discharges into Mud Creek, which is a tributary of the Alapaha River. Both rivers are in the Suwannee River Basin. This section provides an overview of the Withlacoochee service area, the sewer system and the WPCP.

### **2.1 SERVICE AREA DESCRIPTION**

The City of Valdosta is located in the coastal plain of Georgia along the Interstate 75 corridor. Its location approximately fifteen miles north of the Georgia's boundary with Florida allows it to serve as a commercial center of South Georgia. The coastal plain is generally characterized as flat, but the Withlacoochee service area has elevations ranging from 120 feet to 240 feet MSL. Soils in the coastal plain tend to be sandy. The climate can be described as humid subtropical with mild, wet winters and hot, humid summers.

Figure 2-1 shows the collection systems boundaries and locations of the City of Valdosta WPCPs.

### **2.2 WITHLACOOCHEE SERVICE AREA SEWER SYSTEM**

The Withlacoochee WPCP, located at 3352 Wetherington Lane in Valdosta, Georgia receives and treats wastewater from a network of sewer systems in the north and west sections of the City of Valdosta as seen on Figure 2-1. The service area is generally bounded by Highway 84 on the south, Forrest Street and Bemiss Road on the east, and the northern corporate limits of the City of Valdosta. This service area consists of approximately 20 miles of 15 to 54-inch sewers with major interceptors along One Mile Branch, and Three Mile Branch. The 54-inch outfall sewer which delivers all influent flow to the Withlacoochee WPCP lies in the floodplain of the Withlacoochee River and is subject to flooding and direct inflow.




Figure 2-1. City of Valdosta Wastewater Service Areas





### 2.3 WITHLACOOCHEE WPCP

The Withlacoochee WPCP (NPDES permit No. GA 0033235) is currently permitted to discharge to the Withlacoochee River with seasonal effluent limitations. Seasonal flow limitations for the existing Withlacoochee WPCP are listed in Table 2-1. Biochemical oxygen demand, ammonia and total residual chlorine concentrations also vary seasonally.

<b>Table 2-1. Withlacoochee WPCP NPDES Permit Effluent Flow Limitations</b>	
<b>Months</b>	<b>Seasonal monthly discharge flow limitations, mgd</b>
January – April	12
May	10
June – December	8

The Withlacoochee WPCP plant property is at a low elevation adjacent to the Withlacoochee River. The plant receives high peak flow following rain storms as a result of infiltration and inflow into the system, including significant inflow into the 54-inch outfall sewer. Due to heavy rains in April 2009, the plant was underwater and during that time plant flows were estimated at 25 million gallons per day (mgd).





### SECTION 3

## WASTEWATER FLOW CHARACTERISTICS AND IMPROVEMENT OBJECTIVES

This section discusses wastewater projections for the Withlacoochee WPCP service area. The section further identifies wastewater design flows for each facility.

### 3.1 POPULATION AND FLOWS

Population and wastewater flow projections for the Withlacoochee service area in the years 2018, 2038 and build-out (2050) are developed and documented in the City of Valdosta Sewer System Modeling and Capacity Evaluation Report, January 2010 (Sewer System Modeling Report). The sizing of the equalization storage was determined in this engineering report. These projections serve as the basis for developing design flows. An analysis to develop design flows for this project is documented in a report titled Technical Memorandum (TM) No 1 Wastewater Flows dated January 28, 2011. A copy of this Technical Memorandum is included as Appendix B.

Average dry weather wastewater flows for the Withlacoochee service area are projected to increase from 5.16 mgd in year 2008 to 12.94 mgd at build out. These Camp Dresser & McKee (CDM) developed projections represent a 150 percent increase in average dry weather flow over a 42 year period. Build out was set at year 2050. Five-minute peak flow factors ranging from 1.7 to 12.4 times average dry weather flow are reported in the Sewer System Modeling Report. Average dry weather diurnal flow variation for each monitor location is included in the City's SewerCad model of the collection system.

Improvements to the sewer system presented in a separate Preliminary Engineering Report will pump flow directly to the Withlacoochee WPCP through a manifolded force main. Generally, flows converge at two locations in the collection system and will be pumped from those locations: Gornto Road and Remer Lane with the average dry weather flow projections shown in Table 3.1.

<b>Table 3-1. Withlacoochee Basin Average Dry Weather Flow</b>				
<b>Service Area</b>	<b>Average Dry Weather Flow, mgd</b>			
	<b>2008</b>	<b>2018</b>	<b>2038</b>	<b>2050</b>
<b>Remer Lane</b>	3.31	4.76	6.41	7.33
<b>Gornto Road</b>	1.85	2.78	4.55	5.26
<b>Direct to WPCP</b>	0.00	0.10	0.30	0.35
<b>Total, Withlacoochee WPCP</b>	<b>5.16</b>	<b>7.64</b>	<b>11.26</b>	<b>12.94</b>



The City is undertaking a prioritized program to reduce the infiltration and inflow into its collection system. This program is expected to reduce the peak flows to the Withlacoochee WPCP. Therefore, it is appropriate to select a future peaking factor that reflects this reduction. Based on a review of peaking factors for similar sized facilities, a peaking factor of 3.0 times average dry weather flows is used to calculate peak hour flows for the development of long-term improvements to the system. This peaking factor is generally conservative to account for the uncertainty of future reductions of infiltration and inflow into the collection system. Peak hour projections are presented in Table 3-2.

<b>Table 3-2. Withlacoochee Basin Peak Hour Flow</b>				
<b>Service Area</b>	<b>Peak Hour Flow, mgd</b>			
	<b>2008</b>	<b>2018</b>	<b>2038</b>	<b>2050</b>
<b>Remer Lane</b>	9.94	14.27	19.23	21.98
<b>Gornto Road</b>	5.54	8.35	13.66	15.79
<b>Direct to WPCP <sup>1</sup></b>	0.00	0.30	0.90	1.05
<b>Withlacoochee WPCP</b>	<b>15.48</b>	<b>22.92</b>	<b>33.79</b>	<b>38.82</b>

<sup>1</sup>City of Valdosta service area adjacent to WPCP

Facilities sized based on these projections will provide for the future growth needs of the system, and provide additional peak capacity during the interim period, as the Sewer System Rehabilitation Program reduces infiltration and inflow into the system.

### **3.2 DESIGN FLOWS**

The Withlacoochee WPCP Improvements will be designed for a peak hour flow of 40 mgd, the projected 2050 flow. The design flow rates for process units are shown on Drawing No. G-06 Forward Flow Schematic included in Appendix C.



## SECTION 4 PROPOSED FACILITIES

This section presents the proposed facilities for the improvements to the Withlacoochee WPCP. These improvements are being done in conjunction with Sewer System Improvements which will discharge directly to these improvements. Subsection 4.1 presents the proposed facilities. Subsection 4.2 presents projected capital costs, operation and maintenance cost and the schedule for completion of the proposed facilities.

### 4.1 WITHLACOOCHEE WPCP IMPROVEMENTS

#### 4.1.1 Summary of Expansion Concept

The design for the WPCP Improvements involves construction of a new headworks and flow equalization on higher elevation property near the existing Withlacoochee WPCP site. Upon completion of these both Withlacoochee WPCP and sewer system improvements flow will be routed away from the existing 52-inch outfall and pumped directly to the Withlacoochee WPCP headworks in a single 42" force main.

#### 4.1.2 Basis of Design

The following sections present the basis of design for the proposed Withlacoochee WPCP Improvements.

Flow will be routed from the existing collection system directly to the new Withlacoochee WPCP Improvements. The pumping stations and general alignment of the force main, WPCP improvements and the existing Withlacoochee WPCP are shown on Figure 4-1. Table 4-1 presents the basis of design in tabular format. A hydraulic profile, and preliminary drawings of the improvements are included in Appendix C.

Table 4-1. Basis of Design		
Withlacoochee WPCP Improvements		
Item		Design Year 2050
<b>Headworks</b>		
	<b>Coarse Screen</b>	
	Number, total/redundant (2 automatic, 1 manual)	2/1
	Opening Size, inches	0.25
	Screen Width, feet (screen face)	3.5



Table 4-1. Basis of Design		
Withlacoochee WPCP Improvements		
Item		Design Year 2050
	Velocity, feet per second	3
	<b>Grit Removal</b>	
	Concentrator	
	Description	Forced vortex grit chamber
	Number, total/redundant	2/0
	Capacity, each, mgd	20
	Diameter, feet	16
	<b>Grit Pumps</b>	
	Number, total/redundant	4/2
	Capacity, gpm	220
	Motor size, HP	7.5
	<b>Grit Cyclone</b>	
	Description	Dominant free-vortex/secondary boundary layer velocities
	Number, total/redundant	2
	Capacity, gpm	220
	Inlet Size, inches	4
	Overflow Size, inches	6
	<b>Grit Classifier</b>	
	Description	Shafted screw
	Number, total/redundant	2/0
	Capacity, cy/hr	30
	Screw Size, inches	12
	Motor Size, HP	1
	<b>Equalization Tank</b>	
	<b>Tank</b>	
	Volume, MG	6
	Diameter, feet	200
	Straight Side Depth, feet	25
	Description	Pre-stressed concrete
	<b>Tank Mixing System</b>	



**Table 4-1. Basis of Design**

Withlacoochee WPCP Improvements			Design Year 2050
Item			
	Description		Jet Mix Pumps
	Pump Type		Submersible
	Number, total/redundant		4/0
	Capacity each, gpm		6590
	Speed, rpm		1850
	Head, feet		18
	Efficiency, percent		68
	Number jet mix headers		4
	Number Jets/Header		18

#### **4.1.2.1 Headworks**

The headworks structure is designed to function as a barometric loop, maintaining a full pipe in the manifolded force main from the Remer Lane and Gornto Road pump stations. A magnetic flow meter will be installed on the influent line. Wastewater will flow through a coarse screen, with the screenings collected in a waste container. Screened wastewater will flow by gravity to the grit concentrator where the wastewater will be separated into water, organics, and grit. The grit is further dewatered by pumping it to a grit classifier with cyclone. The dewatered grit will be collected in a waste container with the screenings and will be disposed of off-site. De-gritted wastewater will flow to the equalization tank. Provision will be made in the headworks structure to allow for flow directly from the headworks to a new treatment plant in the future.

#### **4.1.2.2 Equalization Storage**

All flow from the headworks will flow through a 6-mg flow equalization tank prior to discharging to the Withlacoochee WPCP. A jet mix system, using recycled water from the tank will keep the contents of the equalization tank mixed, and solids in suspension. To minimize solids accumulation, the tank has a sloped bottom. Flows to the existing Withlacoochee WPCP and recycle back through the jet mixing system will be drawn from the bottom of the tank. An uninstalled spare jet mix pump will be maintained.


#### **4.1.2.3 Gravity Outfall to the Existing WPCP**

After equalization, wastewater flows by gravity to the Existing Withlacoochee WPCP through approximately 4,000 feet of 30-inch HDPE pipe. The general alignment of this outfall is shown



on Figure 4-1. Drawing 0489-01 in Appendix C shows the profile of this pipe. Influent samples will be collected in the splitter box at the existing Withlacoochee WPCP.





**Figure 4-1. Withlacoochee Service Area Sewer System Improvements**





#### **4.1.2.4 Ancillary Facilities**

This section presents a discussion of ancillary facilities utilized in the Withlacoochee WPCP Improvements. These facilities include odor control and electrical.

##### **4.1.2.4.1 Odor Control**

These improvements are located on an isolated site adjacent to a landfill, and property designated for industrial use. Provisions to cover the headworks are provided in the event that an odor control system is needed in the future.

##### **4.1.2.4.2 Electrical**

Primary electrical supply will be from the Georgia Power Company electrical distribution system. In the event of a power interruption, the influent flow will be screened through the manual bar screen, then flow by gravity through the headworks and equalization storage discharging to the existing plant splitter box.

#### **4.2 CONSTRUCTION SEQUENCING**

The following construction sequence summarizes the general order of planned construction activities for the Withlacoochee WPCP improvements. As detailed design progresses, a more detailed construction sequence will be incorporated in construction documents.

The headworks, equalization and force main are located to allow construction to start immediately. Site preparation will be followed by construction of the structures then installation of equipment as soon as it is delivered. Construction will be scheduled for commissioning of these improvements to coincide with completion of construction of the Sewer System Improvements which will supply flow.

Following commissioning, the existing influent lift station and 54-inch influent sewer will be plugged on both ends and abandoned in place.

#### **4.3 PROJECTED COST AND SCHEDULE**

Estimated capital costs for the facilities are summarized in Table 4-2. The City of Valdosta anticipates funding the project through the FEMA or other revenue sources.

<b>Table 4-2. Projected Capital Cost</b>	
<b>Item</b>	<b>Cost, million dollars</b>
Withlacoochee WPCP Improvements	
Design	0.2
Construction	5.0
<b>Total Projected Capital Cost</b>	<b>5.2</b>





Projected annual operation and maintenance costs for the facilities are summarized in Table 4-3.

<b>Table 4-3. Projected Annual Operation and Maintenance Cost</b>	
<b>Item</b>	<b>Average Operation and Maintenance Cost, dollars</b>
<b>Withlacoochee WPCP Improvements</b>	
Labor	16,000
Electric Power	34,000
Maintenance	4,000
Renewal/Capital Replacements	15,000
Other	10,000
<b>Estimated Annual Average O&amp;M</b>	<b>79,000</b>

The City of Valdosta anticipates using a design-bid-build approach for this project, with a plan to have facilities in operation by the end of year 2013. The projected construction schedule for these facilities is outlined in Table 4-4.

<b>Table 4-4. Anticipated Construction Schedule</b>	
<b>Item</b>	<b>Anticipated Date</b>
Detailed Design Complete	April 2012
Bid Opening	June 2012
Construction Contract Issued	July 2012
Construction Completion	October 2013
Testing, Startup and Training Completion	November 2013

# **Appendix A**

## **Environmental Information Document**

# **Appendix B**

## Flow Projections

## Wastewater Flows

### Withlacoochee Water Pollution Control Plant & Sewer System Improvements

Date: January 28, 2011

---

#### PURPOSE

This technical memorandum (TM) defines wastewater flow characteristics to be used in the evaluation of alternatives for the Withlacoochee Water Pollution Control Plant (WPCP) & Sewer System Improvements. Pertinent tables and figures from the report titled City of Valdosta Sewer System Modeling and Capacity Evaluation Report, January 2010 (Sewer System Modeling Report) are included as exhibits in this TM.

#### FINDINGS

Wastewater flows for use in developing the Withlacoochee WPCP & Sewer System Improvements are based on the projections presented in the Sewer System Modeling Report prepared by CDM. The Withlacoochee WPCP collection system is generally divided into two subbasins for the purpose of developing and analyzing collection system improvements. Generally, flows converge at two locations in the collection system, in the area of the abandoned treatment facility off Remer Lane, and Gornto Road, near the Withlacoochee River. Flow projections for these two locations serve as the basis for developing improvement alternatives. Peak and minimum flows for use in developing alternatives are presented in Table 1.

**Table 1. Wastewater Flows for Developing Improvement Alternatives, mgd.**

Subbasin / Sewershed	2008	2018	2038	2050
Remer Lane, Peak Hour	9.94	14.27	19.23	21.98
Remer Lane, Minimum Hour	2.15	3.09	4.16	4.76
Gornto Road, Peak Hour	5.54	8.35	13.66	15.79
Gornto Road, Minimum Hour	0.83	1.25	2.05	2.37

## **BACKGROUND**

Wastewater flow projections for the Withlacoochee Basin of the City of Valdosta wastewater service area in the years 2018, 2038 and build-out (2050) are developed and documented in the Sewer System Modeling Report.

In the previous work, the existing Withlacoochee WPCP service was divided into 14 sewersheds. These sewersheds are shown on Exhibit 1 from the Sewer System Modeling Report. The future service area is divided into an additional 10 sewersheds, and the point of each of these sewershed's loading into the present sewer collection system was identified. These future sewersheds are shown on the Exhibit 2 from the Sewer System Modeling Report.

### **Average Dry Weather Flow Projections**


Exhibit 3 shows Table 3-2 from the Sewer System Modeling Report. It presents average dry weather wastewater flow projections by sewershed for the Withlacoochee WPCP service area. Average dry weather wastewater flows are projected to increase from 5.16 mgd in year 2008 to 12.94 mgd at build out. These CDM developed projections represent a 150 percent increase in average dry weather flow over a 42 year period. Build out was set at year 2050.

### **Monitored Flow Variations**


Five-minute peak flow factors ranging from 1.7 to 12.4 times average dry weather flow are reported in the Sewer System Modeling Report.

Average dry weather diurnal flow variation for each monitor location is included in the City's SewerCad model of the collection system.

## Exhibit 1. Existing Sewer System Sewersheds



## Exhibit 2. Future Sewer System Sewersheds



**Figure 3-2**  
**City of Valdosta**  
**Future Service Areas Loading Points**

### Legend

- Water Pollution Control Plant
- Modeled Trunk Sewers
- Loading Points
- Pump Station
- Sewer < 15" Diameter
- Existing Service Area
- County Bounds



CDM

### Exhibit 3. Average Dry-Weather Flow for Withlacoochee Sewersheds

**Table 3-2: Summary of Future Average Dry-Weather Flow**

Sewershed	2008 Measured ADWF (mgd)	2018 ADWF (mgd)	2038 ADWF (mgd)	Buildout (2050) ADWF (mgd)
<b>Withlacoochee WWTP</b>				
1	0.52	0.54	0.71	0.82
2	0.08	0.08	0.08	0.09
3	0.54	1.19	1.60	1.85
4	0.06	0.17	0.22	0.26
5	0.91	1.28	1.69	1.93
6	0.15	0.18	0.24	0.27
7	0.63	0.94	1.26	1.46
8	0.33	0.66	0.89	1.02
9	0.19	0.49	0.63	0.71
10	0.86	0.86	0.99	1.12
11	0.10	0.16	0.22	0.25
12	0.16	0.22	0.29	0.33
13	0.22	0.24	0.32	0.37
14	0.41	0.53	0.71	0.82
5000	0.00	0.10	0.13	0.15
W1	N/A	N/A	0.17	0.20
W2	N/A	N/A	0.05	0.06
W3	N/A	N/A	0.25	0.28
W4	N/A	N/A	0.03	0.04
W5	N/A	N/A	0.11	0.12
W6	N/A	N/A	0.24	0.28
W7	N/A	N/A	0.12	0.14
W8	N/A	N/A	0.11	0.13
W9	N/A	N/A	0.17	0.20
W10	N/A	N/A	0.034	0.04

Shading indicates that flow projections were lower than monitored flow. The higher flows were substituted.

### WASTEWATER FLOWS FOR ALTERNATIVES DEVELOPMENT

The Withlacoochee WPCP collection system is divided into two subbasins for the purpose of developing and analyzing collection system improvements. Generally, flows converge at two locations in the collection system, in the area of the abandoned treatment facility off Remer Lane, and Gornto Road, near the Withlacoochee River. Table 2 presents the sewersheds in the previous work that are mapped to each of these subbasins. Exhibit 4 shows the boundaries of these subbasins. Gravity flows from Sewershed 11, and approximately 35% of Sewershed 14 discharge



to the line downstream from Remer Lane. In the alternatives, these Sewershed 11 and Sewershed 14 flows will be intercepted and rerouted from the Gornto Road Subbasin into the Remer Lane Subbasin.

**Table 2. Sewersheds in Each Subbasin**

<b>Subbasin</b>	<b>Existing Sewersheds</b>	<b>Future Sewersheds</b>
<b>Remer Lane</b>	5, 6, 7, 8, 9, 10, 11, 14 (35%)	W6
<b>Gornto Road</b>	1, 2, 3, 4, 12, 13, 14 (65%)	W2, W3, W4, W5, W7, W8, W9, W10

Average Dry Weather Flow Projections summarized by subbasin are presented in Table 3.


**Table 3. Withlacoochee Basin Average Dry Weather Flow, mgd**

<b>Subbasin</b>	<b>2008</b>	<b>2018</b>	<b>2038</b>	<b>2050</b>
<b>Remer Lane</b>	3.31	4.76	6.41	7.33
<b>Gornto Road</b>	1.85	2.78	4.55	5.26
<b>Direct to WPCP</b>	0.00	0.10	0.30	0.35
<b>Total, Withlacoochee WPCP</b>	<b>5.16</b>	<b>7.64</b>	<b>11.26</b>	<b>12.94</b>


The City is undertaking a prioritized program to reduce the infiltration and inflow into its collection system. This program is expected to reduce the peak flows that will be conveyed to the Withlacoochee WPCP. Therefore, it is appropriate to select a future peaking factor that reflects this reduction. Exhibit 5 shows peaking factor for various size facilities from Wastewater Engineering: Treatment and Reuse. Based on a review of peaking factors for similar sized facilities, a peaking factor of 3.0 times average dry weather flows is used to calculate peak hour flows for the development of long-term improvements to the system. The basis of the selection of this peaking factor can be seen in Exhibit 5. This peaking factor is generally conservative to account for the uncertainty of future reductions of infiltration and inflow into the collection system. Peak hour projections are presented in Table 4. These projections are illustrated graphically in Exhibit 6.

Facilities sized based on these projections will provide for the future growth needs of the system, and provide additional peak capacity during the interim period, as the Sewer System Rehabilitation Program reduces infiltration and inflow into the system. For example, firm capacity to meet the Remer Lane 2038 peak hour flows of 19.23 mgd, provides infrastructure that is initially capable of conveying peak flows that are approximately 9 mgd higher than projected peak hour wastewater flows using a factor of 3.0. This interim capacity is shown graphically on Exhibits 6 and 7 for the Remer Lane and Gornto Road subbasins.


## Exhibit 4. Withlacoochee WPCP Subbasins



**Figure 3-2**  
**City of Valdosta**  
**Future Service Areas Loading Points**



### Exhibit 5. Peaking Factors for Various Sized Facilities



**FIGURE 5-1**


Hourly peaking factor for domestic wastewater flowrates. Peaking factor is the ratio of maximum hourly flowrate to average flowrate. *Note:* Mgal/d  $\times$  0.043813 = m<sup>3</sup>/s.

Source: Wastewater Engineering Treatment, Disposal, Reuse


**Table 4. Withlacoochee Basin Peak Hour Flow, mgd**

Subbasin / Sewershed	2008	2018	2038	2050
Remer Lane	9.94	14.27	19.23	21.98
Gornto Road	5.54	8.35	13.66	15.79
Direct to WPCP	0.00	0.30	0.90	1.05
Withlacoochee WPCP	15.48	22.92	33.79	38.82


**Exhibit 6. Peak Hour Flows based on a 3.0 peaking factor**



**Exhibit 7. Peak Hour Capacity Remer Lane Subbbasin During Implementation of Sanitary Sewer Rehabilitation Program**




### Exhibit 8. Peak Hour Capacity Gornto Road Subbbasin During Implementation of Sanitary Sewer Rehabilitation Program




In developing and evaluating alternatives, consideration must also be given to the minimum flows from each subbasin. Minimum flows from each subbasin are based on diurnal variations monitored in 2008. Exhibit 9 is a graph of diurnal flow in the Remer Lane subbasin. Minimum hourly flows from the Remer Lane subbasin are approximately 65 percent of average dry weather flow. Exhibit 10 is a graph of diurnal flow in the Gornto Road subbasin. Minimum hourly flows from the Gornto Road subbasin are approximately 45 percent of average dry weather flow. Projected minimum hourly flows are summarized in Table 5.

**Exhibit 9. Diurnal Variation Remer Lane Subbasin**



**Exhibit 10. Diurnal Variation Gornto Road Subbasin**



**Table 5. Minimum Hourly Wastewater Flows for Developing Improvement Alternatives, mgd.**

<b>Subbasin / Sewershed</b>	<b>2008</b>	<b>2018</b>	<b>2038</b>	<b>2050</b>
<b>Remer Lane, Minimum Hour</b>	2.15	3.09	4.16	4.76
<b>Gornto Road, Minimum Hour</b>	0.83	1.25	2.05	2.37

## **ACCEPTANCE**

Signature acknowledges review and acceptance of TM-1 Wastewater Flows by the City of Valdosta:

---

signature


---



date




# **Appendix C**

## Related Documents




WITHLACOOCHEE WATER POLLUTION CONTROL PLANT AND SEWER SYSTEM IMPROVEMENTS		 <p><b>City of Valdosta</b> UTILITIES DEPARTMENT 1016 Myrtle Street; Valdosta, GA 31603 Phone: 229-259-3592</p>		<p><b>PARSONS</b> WATER &amp; INFRASTRUCTURE INC. 3577 PARKWAY LANE, SUITE 100 NORCROSS, GA 30092 PHONE: 770-446-4900 FAX: 770-446-4910</p>		<p>Issue Certification</p> 		<p>Job No. 260384</p> <p>Designed PG</p> <p>Drawn PG</p> <p>Checked XX</p> <p>Reviewed XX</p> <p>Approved XX</p> <p>Reg. No. _____</p> <p>Date 3/16/11</p>		<p>DESIGN DEVELOPMENT REPORT</p> <p>Rev _____</p> <p>Date _____</p> <p>Description _____</p> <p>By _____</p>	
DRAWING NO.		REV		0		2		2011 11:18:09 AM			
G06											



J:\Withlacoochee WTP\Construction Drawings\Phase 1\00\_General\G05 HYDRAULIC PROFILE.dwg





J:\Withlacoochee WTP\Construction Drawings\Phase 1\00\_General\G05 HYDRAULIC PROFILE.dwg

J:\Withlacoochee WTP\Construction Drawings\Phase 1\06\_Mech\02\_Plant\02 Headworks Plan.dwg



WITHLACOOCHEE WATER POLLUTION CONTROL PLANT AND SEWER SYSTEM IMPROVEMENTS		LOWER LEVEL PLAN		DRAWING NO. M02.01	REV 0
City of Valdosta UTILITIES DEPARTMENT 1016 Myrtle Street, Valdosta, GA 31603 Phone: 229-259-3592		Issue Certification		Job No. 260501	By
 PARSONS WATER & INFRASTRUCTURE INC. 3577 PARKWAY LANE, SUITE 100 NORCROSS, GA 30092 PHONE: 770-448-4800 FAX: 770-448-4810				Designed	
				Drawn	
				Checked	
				Reviewed	
				Approved	
				Reg. No.	
				Date	6/7/11
				Rev	A
				Date	
				Description	DESIGN DEVELOPMENT REPORT

J:\Withlacoochee WWP\Construction Drawings\Phase 1\06\_Mech\02\_Plant\02 Headworks Plan.dwg




WITHLACOOCHEE WATER POLLUTION CONTROL PLANT  
AND SEWER SYSTEM IMPROVEMENTS

UPPER LEVEL PLAN



**PARSONS**  
WATER & INFRASTRUCTURE INC.  
3577 PARKWAY LANE, SUITE 100  
NORCROSS, GA 30092  
PHONE: 770-448-4800  
FAX: 770-448-4810

Issue Certification



Job No.	260501
Designed	
Drawn	PG
Checked	XX
Reviewed	XX
Approved	XX
Reg. No.	
Date	6/8/11

Rev	Date	Description	By
A		DESIGN DEVELOPMENT REPORT	



A Con



Issue Certification


**PARSONS**  
WATER & INFRASTRUCTURE, INC.  
3577 PARKWAY LANE, SUITE 100  
NORCROSS, GA 30092  
PHONE: 770-446-4900

Job No. 260501  
Designed

[illegible]



J:\Withlacoochee WWTP\Construction Drawings\Phase 1\00\_General\G08 SITE PLAN - EXISTING WWTP.dwg



SITE PLAN - EXISTING WWTP  
NO SCALE

Job No.	260501	Issue Certification	PARSONS	City of Valdosta	WITHLACOOCHEE WATER POLLUTION CONTROL PLANT AND SEWER SYSTEM IMPROVEMENTS	DRAWING NO.	G08
Designed	PG					REV	0
Drawn	XX						
Checked	XX						
Reviewed	XX						
Approved	XX						
Reg. No.	6/7/11						
Date	6/7/11						
Rev	A						
Date							
Description	DESIGN DEVELOPMENT REPORT						
By							

