

APPENDIX

WATER RATE SCHEDULE

BASE CHARGE:

The monthly base charge is based on the size of the water meter installed and shall be in accordance with the following:

<u>METER SIZE (INCHES)</u>	<u>PRESENT BASE RATE</u>	<u>NEW METER CHARGE</u>
5/8	4.20	350.00
1	6.43	400.00
1 ½	9.49	650.00
2	14.66	775.00
3	39.94	Meters larger than 2-inch are sold for cost of material and labor plus \$75.00.
4	55.57	
6	93.37	
8	137.76	

CONSUMPTION CHARGE:

The consumption charge per one hundred cubic feet of water is:

<u>USER CLASS</u>	<u>PRESENT CHARGE</u>
Residential	1.40

WATER RATE SCHEDULE - Out of City Service:

Water rates for all customers located outside the territorial limits of the City shall equal the in-City rates, as specified in this table, multiplied by two hundred percent (200%).

TABLE WSCM 104

SEWER RATE SCHEDULE

RESIDENTIAL - In City Service

CONSUMPTION CHARGE:

The sewage consumption charge per one hundred cubic feet is two dollars and eighty cents (\$2.80).

BASE RATE

The sewage base rate is four dollars and twenty cents (\$4.20).

TABLE WSCM 105

WEIGHTS OF FITTINGS

(Weights are in pounds and are based on AWWA C153,
M.J. x M.J. Joints, Class 350 Fittings.
Weights do not include accessories)

COMPACT FITTINGS

SIZE	BEND								SLEEVE				
	11 ¼°	22 1/2°	45°	90°					7.5"	9.5"	12"	15"	
4"	16	18	23	27					17		20		
6"	30	32	32	39					28		36		
8"	42	46	46	57					38		46		
10"	58	64	70	89					49		62		
12"	74	84	86	108					56		76		
14"	130	148	164	210						111		140	
16"	158	178	202	264						130		172	
18"													
20"													
24"													
30"													

SIZE	TEE	CRS.	RED.	SIZE	TEE	CRS.	RED.	SIZE	TEE	CRS.	RED.
4" x 4"	32	40		14" x 4"	172						
				14" x 6"	182		100				
6" x 4"	46		24	14" x 8"	206		100				
6" x 6"	56	80		14" x 10"	228		100				
				14" x 12"	234		100				
8" x 4"	60		32	14" x 14"	280	335					
8" x 6"	72		36								
8" x 8"	86	105		16" x 6"	228		124				
				16" x 8"	248		124				
10" x 4"	78		46	16" x 10"	264		124				
10" x 6"	90		47	16" x 12"	280		124				
10" x 8"	105		50	16" x 14"	316		140				
10" x 10"	120	145		16" x 16"	322	385					
12" x 4"	94		58								
12" x 6"	110		60								
12" x 8"	125		60								
12" x 10"	140		64								
12" x 12"	160	215									

TABLE WSCM 110

WEIGHTS OF FITTINGS

(Weights are in pounds and are based on AWWA C110,

M.J. x M.J. Joints, Class 350 Fittings.

Weights do not include accessories.)

STANDARD FITTINGS

SIZE	BEND				CAP	PLUG	TAP PLUG	SLEEVE			
	11 ¼°	22 ½°	45°	90°				7.5"	9.5"	12"	15"
4"	50	50	50	55	15	15	15	35		45	
6"	75	75	75	85	25	25	25	45		65	
8"	110	110	110	125	45	45	45	65		85	
10"	160	160	155	190	60	65	65	85		115	
12"	220	220	215	255	80	85	85	110		145	
14"	275	275	270	340	120	115	115		150		195
16"	345	345	340	430	155	145	145		180		235
18"	430	430	420	545	195	185	185		215		285
20"	540	535	530	680	240	225	225		240		325
24"	770	765	755	1025	345	335	335		320		425

SIZE	TEE	CRS.	RED.	SIZE	TEE	CRS.	RED.	SIZE	TEE	CRS.	RED.
4" x 4"	80	105		14" x 6"	435	475	190	20" x 6"	725	760	
				14" x 8"	450	500	210	20" x 8"	735	790	
6" x 4"	115	140	60	14" x 10"	465	540	230	20" x 10"	755	820	375
6" x 6"	125	160		14" x 12"	495	585	255	20" x 12"	775	860	405
				14" x 14"	520	635		20" x 14"	795	905	430
8" x 4"	165	185	80					20" x 16"	945	1085	470
8" x 6"	175	205	36	16" x 6"	540	575	230	20" x 18"	985	1155	510
8" x 8"	185	235		16" x 8"	550	605	250	20" x 20"	1020	1230	
				16" x 10"	570	645	280				
10" x 4"	235	260	105	16" x 12"	590	685	305	24" x 6"	985	1025	
10" x 6"	250	285	115	16" x 14"	620	735	335	24" x 8"	1000	1045	
10" x 8"	260	310	135	16" x 16"	650	790		24" x 10"	1020	1085	
10" x 10"	310	380						24" x 12"	1030	1110	550
				18" x 6"	590	625		24" x 14"	1055	1155	575
12" x 4"	315	340	135	18" x 8"	605	655	295	24" x 16"	1075	1200	615
12" x 6"	325	360	150	18" x 10"	620	685	325	24" x 18"	1400	1590	660
12" x 8"	340	385	165	18" x 12"	640	725	350	24" x 20"	1450	1675	705
12" x 10"	390	460	190	18" x 14"	755	870	380	24" x 24"	1535	1835	
12" x 12"	410	495		18" x 16"	785	930	415				
				18" x 18"	820	995					

TABLE WSCM 111

SEWER PIPE AIR TESTING TABLE

GRAVITY SEWER PIPES

<u>PIPE SIZE</u>	<u>DEPTH</u>	<u>LENGTH</u>	<u>TEST PRESSURE (PSI)</u>	<u>TEST TIME (MINUTES)</u>
6"	3' to 8.9'	0' – 400'	5	5
6"	9' to 25'	4' – 400'	8	5
8"	3' to 8.9'	0' – 299'	5	5
8"	3' to 8.9'	300' – 400'	5	5
8"	9' to 25'	0' – 299'	8	5
8"	9' to 25'	300' – 400'	8	5
10"	3' to 8.9'	0' – 199'	5	5
10"	3' to 8.9'	200' – 400'	5	5
10"	9' to 25'	0' – 199'	8	5
10"	9' to 25'	200' – 400'	8	5
12"	3' to 8.9'	0' – 400'	5	5
12"	9' to 25'	0' – 400'	8	5
15"	3' to 8.9'	0' to 199'	5	5
15"	3' to 8.9'	200' – 400'	5	5
15"	9' to 25'	0' – 199'	8	5
15"	9' to 25'	200' – 400'	8	5
18"	3' to 8.9'	0' – 199'	5	5
18"	9' to 25'	200' – 400'	8	5

SEWER MANHOLES

<u>DIAMETER</u>	<u>TEST VACUUM</u>	<u>TEST TIME</u>
4-feet	1-inch	60 seconds
5-feet	1-inch	75 seconds
6-feet	1-inch	90 seconds